

1  
Franklin Twp. Board of Health  
Thursday, September 23, 2010

**MINUTES**  
**FRANKLIN TOWNSHIP BOARD OF HEALTH**  
**THURSDAY, SEPTEMBER 23, 2010**  
**8:00 P.M.**

Upon recessing the Township Committee meeting, the Franklin Township Board of Health convened at **8:00 P.M., Thursday, September 23, 2010**. This meeting has been properly noticed in accordance with the Open Public Meetings Act.

Chairperson Linda Jacukowicz called the meeting to order.

Present: Members Scott Bauman, Robert Shockley, Steven Tarshis,  
Vice Chair Robert McGeary, Chair Linda Jacukowicz

Absent: None

Also present: Anthony E. Koester, Esq., Municipal Attorney  
William Burr, P.E., Maser Consulting  
David & Carolyn Davis, Board of Health Applicant  
Stephen E. Parker, P.E. for the applicant Davis  
Douglas Cole, Esq., Attorney for TPA of Pittstown, LLC  
Joseph Perricone, applicant

**ADOPTION OF MINUTES**

Motion to adopt minutes of September 9, 2010.

Moved McGeary Second Bauman

AYES:	Bauman, Tarshis, McGeary, Jacukowicz	NAYS:	None
ABSTAIN:	Shockley	ABSENT:	None

Motion carried.

**DAVID DAVIS (continuation) - BLOCK 34 LOT 6**

Mr. Koester updated the Board: at the last meeting, the Board of Health indicated it's inclination for approval of the septic system waivers subject to the applicant meeting the requirement regarding public notice. An affidavit was provided to the Board of Health Secretary which she deemed adequate. Mr. Koester provided the applicant with assistance in this regard.

Stephen Parker, P.E. and David Davis were sworn in by Mr. Koester prior to providing testimony.

Mr. Parker addressed the issue regarding another soil log being done in the area of the proposed septic field. Since the first two soil logs were so different in depth to groundwater, another was required by the Municipal Engineer to see if there was something more consistent and the possibility of lowering the mound and changing the height and alter the configuration of the system.

Mr. Parker said they did another soil log and unfortunately found it was exactly similar to soil log #1 – a higher groundwater indication which means they are unable to lower the height of the mound and change the design. What's driving the design is the elevation of groundwater. The design is staying the same.

Mr. Parker commented on the waivers requested: mostly setback distances requested at the September 9 hearing which Mr. Koester asked him to reiterate:





4

Franklin Twp. Board of Health  
Thursday, September 23, 2010

**ADJOURNMENT**

Motion to adjourn at 8:43 P.M. in order to reconvene the Township Committee work session.

Moved McGeary Second Bauman All in favor. Motion carried.

Respectfully submitted,

Ursula V. Stryker  
Secretary

**DATE OF ADOPTION:** \_\_\_\_\_